

**IFB-19002 – INSTALLATION OF PZ-27 STEEL SHEET PILING
ADDENDUM # 2**

DUE DATE/TIME: 2:00 PM, CST, MONDAY, FEBRUARY 4, 2019

In reference to the above stated IFB-19002, the following additional information is provided for clarification and/or response to a question received.

Questions:

- Drawing # D-2 list the sheet pile wall to be “55.0’ wide section of PZ-27 sheet piling 30.0’ long”.
- Drawing # D-1.1 & 1.2 list the sheet pile wall to be “ 66.0’ wide section of PZ-27 sheet piling 30.0’ long”.

Response:

The width as shown on sheets D1.1 and D1.2 is correct at 66 feet.

In reference to the above stated request for proposal, all other terms and conditions remain the same.

I HEREBY ACKNOWLEDGE RECEIPT OF ADDENDUM # 2 IN REFERENCE TO THE ABOVE PROJECT.

Company

Representative Signature

Address

Representative (Print Name)

City, State, Zip

Phone

Return Completed Form with Offer