

Service Sink or Curbed Cleaning Facility



➡ 228.147(c)(1)...requires at least one service sink or curbed cleaning facility shall be provided with a floor drain.

➡ 228.143(b)...requires water of sufficient capacity, under pressure, and hot water to be sufficient to meet the peak hot water demands throughout the food establishment.



Orange County Environmental Health and Code Compliance Department

11475-C FM 1442

Orange, Texas 77630

409-745-1463

jscales@co.orange.tx.us

